


Seattle  
Department of Construction and Land Use



William J. Justen, P.E., Director  
Charles Royer, Mayor

March 13, 1981

RE: Passenger Elevator #3669  
AT: 811 N. 130th  
Permit Month: August  
Inspected: 3-4-81

Sterling Manor  
c/o Coldwell Banker & Co.  
1600 Park Pl. Bldg.  
1200 Sixth Ave.  
Seattle, Washington 98101  
Attn: Mr. Kendall

The Seattle Elevator Ordinance No. 108508, and the Washington State Elevator Code establish certain safety standards for the installation and operation of elevators within the City. Inspection of the subject elevator indicates the following corrections must be made:

1. Inspection was made on the elevator inside the hoistway, doors and related equipment. The machine room was omitted at this inspection.
2. S-5111(2). Keys for access to and for the operation of, elevator equipment shall be tagged with identification for their use and retained on the premises.

Provide a key retainer box locked and keyed to the standard City access key.  
(Call 625-2540 for details).

Please notify this department by letter within thirty (30) days when the above corrections will be or have been completed.

Very truly yours,

WILLIAM J. JUSTEN, P.E.  
Director

By:  
JACK S. O'HARA  
City Elevator Inspector

JSO:cd

Seattle  
Department of Construction and Land Use



William J. Justen, P.E., Director  
Charles Royer, Mayor

March 13, 1981

RE: Passenger Elevator #3669  
AT: 811 N. 130th  
Permit Month: August  
Inspected: 3-4-81

Sterling Manor  
c/o Coldwell Banker & Co.  
1600 Park Pl. Bldg.  
1200 Sixth Ave.  
Seattle, Washington 98101  
Attn: Mr. Kendall

The Seattle Elevator Ordinance No. 108508, and the Washington State Elevator Code establish certain safety standards for the installation and operation of elevators within the City. Inspection of the subject elevator indicates the following corrections must be made:

1. Inspection was made on the elevator inside the hoistway, doors and related equipment. The machine room was omitted at this inspection.
2. S-5111(2). Keys for access to and for the operation of, elevator equipment shall be tagged with identification for their use and retained on the premises.

Provide a key retainer box locked and keyed to the standard City access key.  
(Call 625-2540 for details).

Please notify this department by letter within thirty (30) days when the above corrections will be or have been completed.

Very truly yours,

WILLIAM J. JUSTEN, P.E.  
Director

By:  
JACK S. O'HARA  
City Elevator Inspector

JSO:cd