

*Elwood*  
Receipt No.



# ELEVATOR - CONVEYANCE PERMIT

#473503

MICROFILMED

08252

\$89,409.00

Owners Value

City of Seattle - Department of Construction & Land Use  
710 - 2nd Ave - Ste 700  
Seattle, WA 98104-1703

Permit No.

*P6646*

City No.

\$ 525.00

Permit Fee

New  Alteration

City Project No.

CAR 1

Owners No.

*OK*

Address 1900 ALASKAN WAY

(Correct address is the responsibility of the applicant - incorrect addresses are cancelled)

981 04

Site Phone 206-441-6345

User WATERFRONT LANDING - PHASE I

Contractor OTIS ELEVATOR COMPANY

Owner INTRACORP WATERFRONT LANDINGS L.L.C.

13035 GATEWAY DRIVE, SUITE 157

2505 SECOND AVE., SUITE 300

Address SEATTLE, WA 98168

Owner Address SEATTLE, WA 98121

Phone 206-243-8100

Owner Phone 206-625-9226

Application date 8/14/96 By *Mike Mutal*  
I certify that this installation will conform to all applicable codes and ordinances and approved plans. **MIKE MUTAL**

Date Permit Approved 8-27-96 By *W. C. ...*

Date Permit Issued 9-4-96 By *B. ...*

1. Type of Conveyance: Passenger , Freight , Escalator , Dumbwaiter (power/manual doors) , Handicap Lift (type) , Other , Residential
2. Size of Car: Width 6' 8", Length 4' 3", Height 9' 7", Contract Capacity 2500, Speed 150
3. Rise in feet 51' 4 1/2", No. of Stories 6, No. of openings (front) 6 (rear) 0
4. Manufacturer OTIS, Type of machine HYDRAULIC, Machine location \_\_\_\_\_
5. Hoistway Door Mfg. \_\_\_\_\_, Approved Label \_\_\_\_\_, Hourly Rating \_\_\_\_\_
6. Escalator: Width \_\_\_\_\_, Rise \_\_\_\_\_, Run \_\_\_\_\_, Hoistway door unlocking device \_\_\_\_\_
7. Other, indicate \_\_\_\_\_
8. Alteration, describe \_\_\_\_\_

MICROFILMED

## WARNING

Contractor (installer) must call 684-8453 or the area inspector to arrange for a final inspection when the job is completed.

IT IS UNLAWFUL TO PLACE A CONVEYANCE IN OPERATION PRIOR TO FINAL INSPECTION

Final Acceptance Date 4/22/97 (See reverse for previous inspections and comments)

Inspector *Steve Hamilton*

