



**CITY OF SEATTLE
ANALYSIS AND DECISION OF THE DIRECTOR OF
THE SEATTLE DEPARTMENT OF CONSTRUCTION AND INSPECTIONS**

Record Number: 3029611-LU
Applicant Name: Julian Weber
Address of Proposal: 2300 West Emerson Street

SUMMARY OF PROPOSAL

Land Use Application to allow one 6-unit rowhouse and one 3-unit rowhouse (9 units total).
Parking for 9 vehicles proposed. Existing structure to be demolished.

The following approval is required:

SEPA - Environmental Determination (Seattle Municipal Code Chapter 25.05)

SEPA DETERMINATION:

Determination of Non-significance:

- ☒ No mitigating conditions of approval are imposed.
- ☐ Pursuant to SEPA substantive authority provided in SMC 25.05.660, the proposal has been conditioned to mitigate environmental impacts.

SITE AND VICINITY

Site Zone: Lowrise 1 (LR1)

Vicinity Zoning: North: LR1
East: LR1
South: SF5000
West: SF5000

Environmental Critical Areas: None

Site Description: The subject site is located on the northwest corner of W Emerson Street and 23rd Avenue W. The lot proposed for development is comprised of one parcel containing an existing residential structure. The subject lot and lots to the north are zoned Lowrise (LR1). Lots

to the south and west are zoned Single Family (SF5000). The subject site is bound by W Emerson Street to the south, 23rd Avenue W to the east, an alley along the west property line, and adjacent residential developments along the shared north lot line. Across the alley are residential units. W Emerson Street is a collector arterial street. The site contains approximately 11 feet of grade change from the northwest corner, the high point of the site, to the southeast corner, the low point of the site.

PUBLIC COMMENT:

The public comment period ended on April 9, 2018. Comments were received and carefully considered, to the extent that they raised issues within the scope of this review. These areas of public comment related to density and tree retention. Comments were also received that are beyond the scope of this review and analysis.

I. ANALYSIS – SEPA

Environmental review resulting in a Threshold Determination is required pursuant to the State Environmental Policy Act (SEPA), WAC 197-11, and the Seattle SEPA Ordinance (Seattle Municipal Code (SMC) Chapter 25.05).

The initial disclosure of the potential impacts from this project was made in the environmental checklist submitted by the applicant dated 1/18/2018. The Seattle Department of Construction and Inspections (SDCI) has annotated the environmental checklist submitted by the project applicant; reviewed the project plans and any additional information in the project file submitted by the applicant or agents; and any pertinent comments which may have been received regarding this proposed action have been considered. The information in the checklist, the supplemental information, and the experience of the lead agency with the review of similar projects form the basis for this analysis and decision.

The SEPA Overview Policy (SMC 25.05.665 D) clarifies the relationship between codes, policies, and environmental review. Specific policies for each element of the environment, and certain neighborhood plans and other policies explicitly referenced may serve as the basis for exercising substantive SEPA authority. The Overview Policy states in part: "*where City regulations have been adopted to address an environmental impact, it shall be presumed that such regulations are adequate to achieve sufficient mitigation*" subject to some limitations.

Under such limitations/circumstances, mitigation can be considered. Thus, a more detailed discussion of some of the impacts is appropriate.

Short Term Impacts

Construction activities could result in the following adverse impacts: construction dust and storm water runoff, erosion, emissions from construction machinery and vehicles, increased particulate levels, increased noise levels, occasional disruption of adjacent vehicular and pedestrian traffic, a

small increase in traffic and parking impacts due to construction related vehicles, and increases in greenhouse gas emissions. Several construction-related impacts are mitigated by existing City codes and ordinances applicable to the project such as: The Stormwater Code (SMC 22.800-808), the Grading Code (SMC 22.170), the Street Use Ordinance (SMC Title 15), the Seattle Building Code, and the Noise Control Ordinance (SMC 25.08). Puget Sound Clean Air Agency regulations require control of fugitive dust to protect air quality. The following analyzes construction-related noise, air quality, greenhouse gas, as well as mitigation.

Greenhouse Gas Emissions

Construction activities including construction worker commutes, truck trips, the operation of construction equipment and machinery, and the manufacture of the construction materials themselves result in increases in carbon dioxide and other greenhouse gas emissions which adversely impact air quality and contribute to climate change and global warming. While these impacts are adverse, no further mitigation is warranted pursuant to SMC 25.05.675.A.

Construction Impacts - Noise

The project is expected to generate loud noise during demolition, grading and construction. The Seattle Noise Ordinance (SMC 25.08.425) permits increases in permissible sound levels associated with private development construction and equipment between the hours of 7:00 AM and 7:00 PM on weekdays and 9:00 AM and 7:00 PM on weekends and legal holidays in Lowrise, Midrise, Highrise, Residential-Commercial and Neighborhood Commercial zones.

The limitations stipulated in the Noise Ordinance are sufficient to mitigate noise impacts and no additional SEPA conditioning is necessary to mitigate noise impacts per SMC 25.05.675.B.

Environmental Health

The project includes demolition of existing structures. Should asbestos be identified on the site, it must be removed in accordance with the Puget Sound Clean Air Agency (PSCAA) and City requirements. PSCAA regulations require control of fugitive dust to protect air quality and require permits for removal of asbestos during demolition. The City acknowledges PSCAA's jurisdiction and requirements for remediation will mitigate impacts associated with any contamination. No further mitigation under SEPA Policies 25.05.675.F is warranted for asbestos impacts.

Long Term Impacts

Long-term or use-related impacts are also anticipated as a result of approval of this proposal including: greenhouse gas emissions; parking; potential blockage of designated sites from the Scenic Routes nearby; possible increased traffic in the area. Compliance with applicable codes and ordinances is adequate to achieve sufficient mitigation of most long-term impacts and no further conditioning is warranted by SEPA policies. However, greenhouse gas warrants further analysis.

Greenhouse Gas Emissions

Operational activities, primarily vehicular trips associated with the project's energy consumption, are expected to result in increases in carbon dioxide and other greenhouse gas emissions which adversely impact air quality and contribute to climate change and global warming. While these impacts are adverse, no further mitigation is warranted pursuant to SMC 25.05.675.A.

DECISION – SEPA

This decision was made after review by the responsible official on behalf of the lead agency of a completed environmental checklist and other information on file with the responsible department. This constitutes the Threshold Determination and form. The intent of this declaration is to satisfy the requirement of the State Environmental Policy Act (RCW 43.21.C), including the requirement to inform the public of agency decisions pursuant to SEPA.

- ☒ Determination of Non-Significance. This proposal has been determined to not have a significant adverse impact upon the environment. An EIS is not required under RCW 43.21.030(2) (c).
- ☐ Mitigated Determination of Non-Significance. This proposal has been determined to not have a significant adverse impact upon the environment. An EIS is not required under RCW 43.21.030(2) (c).

The lead agency for this proposal has determined that it does not have a probable significant adverse impact on the environment. An environmental impact statement (EIS) is not required under RCW 43.21C.030 (2)(c). This decision was made after review of a completed environmental checklist and other information on file with the lead agency. This information is available to the public on request.

This DNS is issued after using the optional DNS process in WAC 197-11-355 and Early review

CONDITIONS – SEPA

None.

Lindsay King, Land Use Planner Date: September 13, 2018
Seattle Department of Construction and Inspections

LK:bg

King/3029611-LU

IMPORTANT INFORMATION FOR ISSUANCE OF YOUR MASTER USE PERMIT

Master Use Permit Expiration and Issuance

The appealable land use decision on your Master Use Permit (MUP) application has now been published. At the conclusion of the appeal period, your permit will be considered “approved for issuance”. (If your decision is appealed, your permit will be considered “approved for issuance” on the fourth day following the City Hearing Examiner’s decision.) Projects requiring a Council land use action shall be considered “approved for issuance” following the Council’s decision.

The “approved for issuance” date marks the beginning of the **three year life** of the MUP approval, whether or not there are outstanding corrections to be made or pre-issuance conditions to be met. The permit must be issued by SDCI within that three years or it will expire and be cancelled. (SMC 23-76-028) (Projects with a shoreline component have a **two year life**. Additional information regarding the effective date of shoreline permits may be found at 23.60.074.)

All outstanding corrections must be made, any pre-issuance conditions met and all outstanding fees paid before the permit is issued. You will be notified when your permit has issued.

Questions regarding the issuance and expiration of your permit may be addressed to the Public Resource Center at prc@seattle.gov or to our message line at 206-684-8467.