

Revised Schedule

Addition to Previous Schedule

2018 SBC



SDCI Geotechnical Inspections Schedule

Project Number 6771337-CN

Date 12/14/2021 3:52 PM

Project Address 229 BROADWAY E
SEATTLE, WA 98102

SDCI Plan Examiner Pao Huang

**Architect
Engineer**

**Architect Phone
Engineer Phone**

Prior to issuance of a building permit, the owner or owner's agent shall appoint an inspection agency and shall sign and submit this form to the building official.

Property Owner or Owner's Agent Signature

I hereby certify that the geotechnical engineer named below has been engaged to perform the special inspections outlined below as required by the Seattle Building Code. It is the responsibility of the owner or the owner's designee to notify the inspection agency in a timely manner when the inspections listed below are required.

Signature	Title	Date	Phone
PANGEO INC			(206) 262-0370
Geotechnical Engineering Firm Name			Geotechnical Engineering Firm Phone

Required Special Inspections

Inspection Type	Description
1. Erosion Control - Temporary	
2. Soldier Pile Installation	
3. Shoring Instl/Prfrm Monitoring	Shoring deflection monitoring
4. Monitor Adjacent Building Settlement	South building, due to excavation
5. Soil Bearing Verification	6000 psf
6. Subsurface Drainage Installation	
7. Verify Fill & Compaction	Proper backfill for excavated area

Call (206) 684-8860 to schedule a pre-construction conference before the start of construction

Revised Schedule

Addition to Previous Schedule

2018 SBC



SDCI Statement of Structural Special Inspection

Project Number 6771337-CN

Date 12/14/2021 3:52 PM

Project Address 229 BROADWAY E
SEATTLE, WA 98102

SDCI Plan Examiner Nouri Samiee

Architect
Engineer

Architect Phone
Engineer Phone

Prior to issuance of a building permit, the owner, architect, or engineer acting on behalf of the owner shall appoint an inspection agency and shall sign and submit this form to the building official.

Property Owner, Architect, or Engineer Signature

I hereby certify that the engineering firm and inspection agency named below has been engaged to perform the special inspections outlined below as required by the Seattle Building Code. It is the responsibility of the owner or the owner's designee to notify the inspection agency in a timely manner when the inspections listed below are required.

Signature

Title

Date

Phone

Inspection Agency Name

Inspection Agency Phone

Required Special Inspections

Inspection Type	Description
1. Wood Seismic	
2. High Strength Hold Down System	
3. Reinforced Concrete - Cip	
4. Pt Prestressed Concrete	

Call (206) 684-8860 to schedule a pre-construction conference before the start of construction